

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 06/25

Dated: 11/06/2025

It is certified that an inspection team headed byDr. Praful Verma.....

(Name of Officers with designation) from ...M.O.I.C. KHARKHAUDA PHED

inspected the ...Doon Public School, Kaul Road, Kharkhauda, Meerut

(Name & Address of the school) on 11/06/2025... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. G.W.D.P.S./156/2025060/dated 04/06/2025

of NTR Laboratory Pvt. Ltd. (PHED Lab) certified that the

Doon Public School, Kaul Road Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31 May 2026

Signature with Seal: 

Name : DR. PRAFUL VERMA.

Designation : M.O.I.C.

Name & Address of the Office / Department :

प्रमारी चिकित्सा अधिकारी

सामु. स्वा. केन्द्र


खरखौदा, मेरठ

To

.....

(Name & Address of the Institution)


Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Principal

Doon Public School

Kaul, Kharkhauda Road, Meerut



Manager

Doon Public School

Kaul, Kharkhauda Road, Meerut



NIR LABORATORY Pvt. Ltd

(Formerly Known as Neon Industrial Testing & Research Laboratory)

An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified

Laboratory : 205 A-B, Rajpura, Mawana Road, Near Subhash Inter College Meerut

Mobile : 8218221131, 8449335841, Website : www.nirlaboratory.in, E-mail : nirlaboratory@gmail.com

TEST REPORT

REPORT NO.		GWDPS/156120250601-01		PAGE		1 of 1	
SERVICE REQUEST NO.		GW/NIR/1561		SERVICE REQUEST DATE		01.06.2025	
REPORT ISSUE DATE		04.06.2025		SAMPLE RECD. ON		01.06.2025	
NAME & ADDRESS OF CUSTOMER				SAMPLE DETAILS			
M/s- Doon Public School Kaul Road Kharkhauda Meerut (U.P.)- 245206				Description : One Ground water sample received us by client on : 01.06.2025			
				Sample Marking : Ground water			
				Sample Procedure : IS:3025			
				Sample Quantity & Packing: 1.5Ltr. & Plastic Bottle			
				Analysis Done on : 01.06.2025 to 04.06.2025			
TEST RESULT				Standards		(IS:10500-2012) Drinking	
WATER QUALITY ANALYSIS				limit		water/ground water	
S.No.	Parameter	Result	Unit	Desirable. Limit	Permissible. Limit	Test method	
1.	Turbidity	<1.0	NTU	1.0max	5.0max	IS:3025(P-10)	
2.	pH	7.44	—	6.5-8.5	No Relaxation	IS:3025(P-11)	
3.	Total Dissolved Solids	412	mg/l	500	2000	IS:3025(P-16)	
4.	Total Hardness (as CaCO ₃)	316.3	mg/l	200	600	IS:3025(P-21)	
5.	Calcium (as Ca)	52.88	mg/l	75	200	IS:3025(P-40)	
6.	Chloride (as Cl)	15.2	mg/l	250	1000	IS:3025(P-32)	
7.	Sulphate (as SO ₄)	5.45	mg/l	200	400	IS:3025(P-24)	
8.	Total Alkalinity (asCaCO ₃)	326.8	mg/l	200	600	IS:3025(P-23)	
9.	Fluoride (as F)	0.11	mg/l	1.0	1.5	IS: 3025(P-60)	
10.	Electrical Conductivity	780	µs/cm	Not Specified	Not Specified	IS: 3025(P-14)	
11.	Iron (as Fe)	0.12	mg/l	0.3	No Relaxation	IS: 3025(P-53)	
12.	Magnesium (as Mg)	39.45	mg/l	30.0	100	IS: 3025(P-46)	
13.	Nitrate (as No ₃)	2.6	mg/l	45.0	No Relaxation	IS: 3025(P-34)	
14.	Phosphate (as Po ₄)	< 0.4	mg/l	Not Specified	Not Specified	IS: 3025(P-31)	

End of Report



[Signature]

Principal

Doon Public School
Kaul, Kharkhauda Road, Meerut



[Signature]

Manager

Doon Public School
Kaul, Kharkhauda Road, Meerut

Note:- 1. The Sample will be stored up to 21 days (in case of non perishable items only) from the date of issue of the test report. 2. The results given above are related to the tested sample and mentioned parameters. Endorsement of Product if neither inferred nor implied. 3. Total liability of our works is limited to invoiced Amount. 4. This report can not be used as evidence in a court of law without the written approval of the lab. 5. Certificate shall not be reproduced except in full, without the written approval of the Laboratory. 6. Any sort of play by the customer with the date of this certificate shall be illegal.